

# SLIDING FIRE DOORS

## Important Notes:

1. Sliding fire doors are a low cycle designed assembly specifically NOT intended for every day use.
2. They are emergency doorsets *tested* to AS1530.4, *installed* in accordance with AS1905.1 and *actuated* in accordance with NCC/BCA C3.6 in a fire event only.
3. Other than a fire event, Sliding Fire Doors should only be operated during commission, maintenance & testing periods.
4. Should regular closure be required we recommend a high cycle rated non-fire door assembly be added to the non-slider side of the opening.
5. It is important to note that performance warranty may be rendered void, to the extent permitted by law, should the sliding fire door be operated /actuated beyond the limits outlined above.
6. Maintenance in accordance with AS1851 and the manufacturer's recommendations is essential to the ongoing performance of these doorsets.

